

ROOFING ACCESSORIES

Description	
Wall and Edge Terminations	Duro-Last®-approved termination in accordance with current Duro-Last specifications and details.
Parapet Wall Flashings	Anchor membrane at the base of walls and expansion joints using approved plates and fasteners in accordance with current Duro-Last specifications and details. Parapet membranes must be a minimum of 60 mil (1.52 mm) for 25- and 30-year warranties.
Penetrations	Flash with Duro-Last custom-fabricated flashings, membrane, or where applicable, Duro-Last Liquid-Applied Flashing. Anchor the membrane at the base of curbs, stacks, and penetrations using approved plates and fasteners in accordance with current Duro-Last specifications and details. Penetration flashings must be a minimum of 50 mil (1.27 mm) for 25- and 30-year warranties. Stack Flashings and Drain Boots cannot be field-fabricated.
Corners	Duro-Last custom-fabricated Outside Corners are required and cannot be field-fabricated. Duro-Last custom-fabricated Inside Corners are not required and may be field-fabricated. Refer to current Duro-Last specifications and Detail 1180.
Caulk	Apply only Duro-Caulk® Plus or Duro-Caulk Advanced in accordance with current Duro-Last specifications and details.
Sealants	Apply only Duro-Caulk Plus, Duro-Caulk Advanced, Duro-Mastic®, SB-240 Mastic, or approved sealants in accordance with current Duro-Last specifications and details.
Peel Stops (Adhered ONLY)	Refer to Detail AS9060 to determine peel stop requirements.

DISCLAIMER

This document is meant as a quick reference and may not include details necessary for project completion. Refer to the full Duro-Last specifications or contact the Duro-Last Engineering Services Department for additional information or assistance.