



Note 1: A 1/4-inch gap is required between sections of Duro-Last Termination Bar.

Note 2: Gutter strap spacing per gutter manufacturer's instructions.

Note 3: Wood nailers must withstand a minimum force of 180 pounds per lineal foot (per building code). Any pull values greater than 270 pounds will allow for a fastener spacing of 18 inches on center. Pull values less than 270 pounds will require additional fasteners. **The installing contractor is responsible for meeting building codes.**

Note 4: Refer to specifications for vapor barrier, insulation and cover board requirements.

| | |
|----------------------|--|
| REVISED: N/A | EDGE DETAIL FOR ADHERED NON-FLEECE SYSTEMS |
| PREVIOUS: 01/23/2024 | TERMINATION BAR INTO GUTTER |
| SCALE: NONE | NEW CONSTRUCTION OR RE-ROOF |