



Note 1: The mansard slope must be a minimum of 3 in./ft (1:4).

Note 2: The membrane must terminate a minimum of 5 in. (127 mm) onto the mansard.

Note 3: Metal termination details required in certain Florida counties.

REVISED: N/A	TPO GENERAL DETAIL FOR MECHANICALLY FASTENED SYSTEMS
PREVIOUS: 02/12/2025	TERMINATION ON MANSARD ROOFS
SCALE: NONE	RE-ROOF