



Note 1: All field welds must be a minimum of 1-1/2 in. (40 mm) wide.

Note 2: Refer to General Requirements for wood nailer requirements.

Note 3: Refer to specifications for vapor barrier, insulation, and cover board requirements.

REVISED: N/A	TPO GENERAL DETAIL FOR MECHANICALLY FASTENED SYSTEMS
PREVIOUS: 02/14/2025	DECK-LEVEL EXPANSION JOINT
SCALE: NONE	NEW CONSTRUCTION OR RE-ROOF