



Note 1: The use of this detail is not allowed on adhered applications.

Note 2: This detail may also be used on parapet walls.

Note 3: An overlap of 1-1/2 in. (40 mm) will be required between sections of edging. A bead of approved caulk is required in each overlap.

Note 4: All field welds must be a minimum of 1-1/2 in. (40 mm) wide.

Note 5: Refer to General Requirements for wood nailer requirements.

Note 6: Refer to specifications for vapor barrier, insulation, and cover board requirements.

REVISED: N/A	TPO EDGE DETAIL FOR MECHANICALLY FASTENED SYSTEMS
PREVIOUS: 05/15/2025	METAL DRIP EDGE
SCALE: NONE	NEW CONSTRUCTION OR RE-ROOF