



Note 1: Overlap each 10 ft (3 m) length of base by 1 in. (25 mm). Overlap the covers by 1-1/2 in. (40 mm) utilizing the pre-notched end on 10 ft (3 m) lengths.

Note 2: Refer to General Requirements for wood nailer requirements.

Note 3: Refer to specifications for vapor barrier, insulation, and cover board requirements

| | |
|----------------------|---|
| REVISED: 06/16/2026 | TPO EDGE DETAIL FOR MECHANICALLY FASTENED SYSTEMS |
| PREVIOUS: 07/03/2025 | ALLTERM® |
| SCALE: NONE | NEW CONSTRUCTION OR RE-ROOF |