



Note 1: Precaution must be taken to ensure that all deck-to-wall transitions are sealed.

Note 2: All field welds must be a minimum of 1-1/2 in. (40 mm) wide.

Note 3: Refer to specifications for vapor barrier, insulation, and cover board requirements.

Note 4: Nailers and approved sealant to be level with opening and extend 2 in. (51 mm) past each side of opening. Fasten with approved fasteners spaced 12 in. (305 mm) on center (minimum of 3).

REVISED: N/A	TPO DRAINAGE DETAIL FOR MECHANICALLY FASTENED SYSTEMS
PREVIOUS: 02/17/2025	SINGLE-SKIRTED TPO-COATED METAL SCUPPER
SCALE: NONE	NEW CONSTRUCTION OR RE-ROOF