



Note 1: Vented Ridge Cap comes in 10-ft (3-m) lengths with a factory-welded 6-in. (152-mm) skirt on each side. Splice plates are used to join sections.

Note 2: For all construction types, contractor shall follow building codes to determine opening size needed underneath the Vented Ridge Cap.

Note 3: Duro-TECH membrane must be installed prior to installation of Vented Ridge Cap.

Note 4: 16-gauge support chair brackets are required at 5 ft (1.5 m) on center intervals.

Note 5: Refer to product data sheet for area of venting requirements.

Note 6: All field welds must be a minimum of 1-1/2 in. (40 mm) wide.

Note 7: Refer to specifications for vapor barrier, insulation, and cover board requirements.

REVISED:	N/A	TPO VENT DETAIL FOR MECHANICALLY FASTENED SYSTEMS
PREVIOUS:	05/21/2025	VENTED RIDGE CAP
SCALE:	NONE	NEW CONSTRUCTION OR RE-ROOF