



Note 1: All field welds must be a minimum of 1-1/2 in. (40 mm) wide.

Note 2: Splice cleats are required when face size is 4 in. (102 mm) or greater. Splice cleats are installed 24 in. (610 mm) on center using 4 approved fasteners. Splice cleats must be located at each joint.

Note 3: Approved fasteners are spaced no greater than 6 in. (152 mm) on center.

Note 4: When more than one piece of Arched Drip Edge is used, install the last piece centered at the top of the arch.

Note 5: This detail requires the 6 in. (152 mm) wide membrane stripping to be field welded.

Note 6: Edges are pre-notched to allow for an overlapping joint. Apply an approved sealant at all joints as shown above.

Note 7: Refer to General Requirements for wood nailer requirements.

REVISED: N/A	TPO EDGE DETAIL FOR MECHANICALLY FASTENED SYSTEMS
PREVIOUS: 05/16/2025	ARCHED DRIP EDGE WITH SPLICE CLEAT
SCALE: NONE	NEW CONSTRUCTION OR RE-ROOF