



Note 1: Membrane fastening at deck-to-wall transitions and walls must be same as per respective zones that area is located within (field, perimeter, corner).

Note 2: Refer to Detail 6010 for tab spacing.

Note 3: All field welds must be a minimum of 1-1/2 in. (40 mm) wide.

Note 4: Refer to specifications for vapor barrier, insulation, and cover board requirements.

REVISED: N/A	TPO LIGHTNING PROTECTION DETAIL FOR MECHANICALLY FASTENED SYSTEMS
PREVIOUS: 02/12/2025	LIGHTNING PROTECTION ON WALL
SCALE: NONE	NEW CONSTRUCTION OR RE-ROOF