



Note 1: This detail can only be used on parapet when termination over the parapet edge is not permissible or possible.

Note 2: Skirt must meet the mil thickness necessary for the desired warranty term.

Note 3: All field welds must be a minimum of 1-1/2 in. (40 mm) wide.

Note 4: Strip Mastic must be within 1/2 in. (13 mm) of outside parapet edge. Ensure that Duro-Edge covers Strip Mastic.

Note 5: Membrane fastening at parapets must be same as per respective zones that area is located within (field, perimeter, corner).

Note 6: A 1/8 in. (3 mm) gap is required between sections of Duro-Edge.

Note 7: Each section of Duro-Edge must have an approved fastener and 3-Inch Metal Plate fastened within 1 in. (25 mm) of each end.

REVISED:	N/A	TPO PARAPET DETAIL FOR MECHANICALLY FASTENED SYSTEMS
PREVIOUS:	05/21/2025	DURO-EDGE
SCALE:	NONE	NEW CONSTRUCTION OR RE-ROOF