



- Note 1: Finished detail must **not** impede the drainage or flow of water.
- Note 2: Tie-in detail for all flat surfaces. When tie-in is across metal flutes, the use of Detail TAS1070 will be required in conjunction with Detail TAS1090.
- Note 3: Refer to General Requirements for wood nailer requirements.
- Note 4: Refer to specifications for vapor barrier, insulation, and cover board requirements.
- Note 5: All field welds must be a minimum of 1-1/2 in. (40 mm) wide.

REVISED: N/A	TPO GENERAL DETAIL FOR ADHERED NON FLEECE SYSTEMS
PREVIOUS: 04/13/2026	SINGLE-PLY ROOF TIE-IN
SCALE: NONE	RE-ROOF