



- Note 1: Membrane must be fastened around the perimeter of the drain as per respective zone the drain is located within (field, perimeter, corner). No less than one fastener per drain.
- Note 2: The openings in the composite drain rings (CDR) must face in opposite directions. Sealant and CDRs are to match locations.
- Note 3: The top of the CDRs must be a minimum of 2 in. (51 mm) from the top of the overflow drain.
- Note 4: All field welds must be a minimum of 1-1/2 in. (40 mm) wide.
- Note 5: Refer to specifications for vapor barrier, insulation, and cover board requirements.

REVISED:	N/A	TPO DRAINAGE DETAIL FOR ADHERED NON FLEECE SYSTEMS
PREVIOUS:	09/26/2025	OVERFLOW DRAIN
SCALE:	NONE	NEW CONSTRUCTION OR RE-ROOF