



Note 1: Precaution must be taken to ensure that all deck-to-wall transitions are sealed.

Note 2: Metal flange is back-sealed with factory-applied sealant. Remove paper backing when ready to install scupper.

Note 3: All field welds must be a minimum of 1-1/2 in. (40 mm) wide.

Note 4: Refer to specifications for vapor barrier, insulation, and cover board requirements.

REVISED:	N/A	TPO DRAINAGE DETAIL FOR ADHERED NON FLEECE SYSTEMS
PREVIOUS:	09/26/2025	SINGLE SKIRTED TPO-COATED METAL SCUPPER WITH FLANGE
SCALE:	NONE	NEW CONSTRUCTION OR RE-ROOF