



Note 1: Precaution must be taken to ensure that all wall-to-deck transitions are sealed.

Note 2: All field welds shall be a minimum of 1-1/2 inches wide.

Note 3: Refer to specifications for vapor barrier, insulation and cover board requirements.

REVISED: 05/11/2017

DRAINAGE DETAIL FOR MECHANICALLY FASTENED SYSTEMS

PREVIOUS: 01/01/2009

SINGLE SKIRTED VINYL-COATED METAL SCUPPER

SCALE: NONE

NEW CONSTRUCTION OR RE-ROOF