



Note 1: This detail cannot be used on drains larger than 2 inches in diameter.

Note 2: The membrane shall be terminated through the drain pipe flange and directly to the deck as shown above. The membrane cannot be terminated through insulation, existing roofs or recover boards.

Note 3: All field welds shall be a minimum of 1-1/2 inches wide.

Note 4: Refer to specifications for vapor barrier, insulation and cover board requirements.

| | | |
|-----------|----------|---|
| REVISED: | 11/07/17 | DRAINAGE DETAIL FOR MECHANICALLY FASTENED SYSTEMS |
| PREVIOUS: | 07/28/17 | 2-INCH DRAIN ADAPTER |
| SCALE: | NONE | NEW CONSTRUCTION OR RE-ROOF |