



Note 1: Tie-in detail for all flat surfaces. The use of Detail Drawing 1070 will be required in conjunction with Detail Drawing 1080 when tie-in is across metal flutes.

Note 2: All field welds shall be a minimum of 1-1/2 inches wide.

Note 3: Refer to specifications for vapor barrier, insulation and cover board requirements.

REVISED: 01/31/2017	GENERAL DETAIL FOR MECHANICALLY FASTENED SYSTEMS
PREVIOUS: 01/01/2009	ASPHALT ROOF TIE-IN
SCALE: NONE	RE-ROOF