



Note 1: The mansard slope must be a minimum of 3 inches vertically for every 12 inches horizontally.

Note 2: The membrane must terminate a minimum of 5 inches onto the mansard.

Note 3: Metal termination details required in certain Florida counties.

REVISED: 05/26/2017	GENERAL DETAIL FOR MECHANICALLY FASTENED SYSTEMS
PREVIOUS: 07/20/2016	TERMINATION ON MANSARD ROOFS
SCALE: NONE	RE-ROOF