



Note 1: All field welds shall be a minimum of 1-1/2 inches wide.

Note 2: A wood nailer is required if 1 inch of insulation or greater is used. The top of the wood nailer is to be flush with the top of the insulation. Wood nailers must withstand a minimum force of 180 pounds per lineal foot (per building code). Any pull values greater than 270 pounds will allow for a fastener spacing of 18 inches on center. Pull values less than 270 pounds will require additional fasteners. **The installing contractor is responsible for meeting building codes.**

Note 3: Refer to specifications for vapor barrier, insulation and cover board requirements.

REVISED:	10/20/17	GENERAL DETAIL FOR MECHANICALLY FASTENED SYSTEMS
PREVIOUS:	07/18/17	DECK-LEVEL EXPANSION JOINT
SCALE:	NONE	NEW CONSTRUCTION OR RE-ROOF