



Note 1: This detail may also be used on parapet walls.

Note 2: A 1/4-inch gap is required between sections of Duro-Last vinyl Fascia Bar. A 1-inch gap is required between sections of Duro-Last vinyl Fascia Cover.

Note 3: Joints in vinyl Fascia Bar must be offset by a minimum of 12 inches from joints in the vinyl Fascia Cover. Use Fascia Clips to cover each vinyl Fascia Cover joint.

Note 4: All vertical applications require approved Duro-Last caulk to be applied on both sides of the Fascia System.

Note 5: The Fascia System is not to be used as a gravel/water stop. Fascia System and caulk must be located below roof line.

Note 6: Wood nailers must withstand a minimum force of 180 pounds per lineal foot (per building code). Any pull values greater than 270 pounds will allow for a fastener spacing of 18 inches on center. Pull values less than 270 pounds will require additional fasteners. **The installing contractor is responsible for meeting building codes.**

Note 7: Refer to specifications for vapor barrier, insulation and cover board requirements.

REVISED:	07/19/17	EDGE DETAIL FOR MECHANICALLY FASTENED SYSTEMS
PREVIOUS:	07/19/17	4-INCH VINYL FASCIA SYSTEM
SCALE:	NONE	NEW CONSTRUCTION OR RE-ROOF