



Note 1: The use of this detail is not allowed on adhered applications.

Note 2: This detail may also be used on parapet walls.

Note 3: Refer to Detail Drawing 3080 for installation of skirt and joint clips.

Note 4: A 1-inch gap is required between sections of Duro-Last vinyl Drip Edge.

Note 5: All field welds shall be a minimum of 1-1/2 inches wide.

Note 6: Wood nailers must withstand a minimum force of 180 pounds per lineal foot (per building code). Any pull values greater than 270 pounds will allow for a fastener spacing of 18 inches on center. Pull values less than 270 pounds will require additional fasteners. **The installing contractor is responsible for meeting building codes.**

Note 7: Refer to specifications for vapor barrier, insulation and cover board requirements

REVISED:	07/20/17	EDGE DETAIL FOR MECHANICALLY FASTENED SYSTEMS
PREVIOUS:	07/20/17	4-INCH VINYL DRIP EDGE
SCALE:	NONE	NEW CONSTRUCTION OR RE-ROOF