



Note 1: The use of this detail is not allowed on adhered applications.

Note 2: This detail may also be used on parapet walls.

Note 3: An overlap of 1-1/2 inches will be required between sections of metal cap. A bead of caulk is required in each overlap.

Note 4: All field welds shall be a minimum of 1-1/2 inches wide.

Note 5: Wood nailers must withstand a minimum force of 180 pounds per lineal foot (per building code). Any pull values greater than 270 pounds will allow for a fastener spacing of 18 inches on center. Pull values less than 270 pounds will require additional fasteners. **The installing contractor is responsible for meeting building codes.**

Note 6: Refer to specifications for vapor barrier, insulation and cover board requirements.

REVISED: 02/02/2017	EDGE DETAIL FOR MECHANICALLY FASTENED SYSTEMS
PREVIOUS: 01/01/2009	ENVELOPED TERMINATION BAR ON CANT
SCALE: NONE	NEW CONSTRUCTION OR RE-ROOF