



Note 1: A 1/8 in. gap is required between sections of cleat.

Note 2: Each section of cover must overlap 1-1/2 in.

Note 3: Each section of hook strip must overlap 1-1/2 in.

Note 4: Stagger all seams by a minimum of 12 in. between cleat, hook strip and cover.

Note 5: This detail may also be used on parapet walls.

Note 6: If used in a gutter, back-seal membrane with an approved sealant and fasten 6 in. on center with approved fasteners.

Note 7: All field welds must be a minimum of 1-1/2 in. wide.

Note 8: Refer to General Requirements for wood nailer requirements.

Note 9: Refer to specifications for vapor barrier, insulation, and cover board requirements.

REVISED: 10/31/2025	METAL EDGE DETAIL FOR MECHANICALLY FASTENED SYSTEMS
PREVIOUS: 01/11/2022	T-EDGE ADVANCED
SCALE: NONE	NEW CONSTRUCTION OR RE-ROOF