



Note 1: Water must not be allowed to pond within pitch pan. Ensure that approved Duro-Last self-leveling sealant is level with top of curb. Cover with approved Duro-Last caulk to slope to outside of pitch pan.

Note 2: Deck membrane shall be fastened around perimeter of roof penetration as per respective zone the pitch pan is located within (field, perimeter, corner).

Note 3: Termination Bar shall have an approved Duro-Last fastener within 1 inch of each corner.

Note 4: Mechanical lines must have a minimum of 1/4-inch clearance between objects or pitch pan edges.

Note 5: All field welds shall be a minimum of 1-1/2 inches wide.

Note 6: Refer to specifications for vapor barrier, insulation and cover board requirements.

REVISED:	11/10/17	ROOF PENETRATION DETAIL FOR MECHANICALLY FASTENED SYSTEMS
PREVIOUS:	08/04/17	PITCH PAN - OPTION 2
SCALE:	NONE	NEW CONSTRUCTION OR RE-ROOF