



Note 1: Deck membrane shall be fastened around the perimeter of the roof access hatch as per the respective zone the roof access hatch is located within (field, perimeter, corner).

Note 2: Flashing membrane must loop over the foam backer rod. Foam backer rod shall be of sufficient size to compress when installed.

Note 3: All field welds shall be a minimum of 1-1/2 inches wide.

Note 4: Refer to specifications for vapor barrier, insulation and cover board requirements.

REVISED:	11/10/17	ROOF PENETRATION DETAIL FOR MECHANICALLY FASTENED SYSTEMS
PREVIOUS:	08/04/17	ROOF ACCESS HATCH - OPTION 1
SCALE:	NONE	NEW CONSTRUCTION OR RE-ROOF