



Note 1: This detail is required around heat stacks that exceed 120° F, including all insulated chimney stacks. A minimum of 1-inch air space is required between the metal collar and heat stack. The canopy must be positioned to allow adequate air flow above the termination.

Note 2: Lead flashings must be removed prior to installing Duro-Last Stack Flashings.

Note 3: Deck membrane shall be fastened around the perimeter of the Duro-Last Stack Flashing as per the respective zone the Duro-Last Stack Flashing is located within (field, perimeter, corner), no less than one fastener per flashing.

Note 4: All field welds shall be a minimum of 1-1/2 inches wide.

Note 5: Refer to specifications for vapor barrier, insulation and cover board requirements.

REVISED: 02/02/2017	ROOF PENETRATION DETAIL FOR MECHANICALLY FASTENED SYSTEMS
PREVIOUS: 01/01/2009	HEAT STACK
SCALE: NONE	NEW CONSTRUCTION OR RE-ROOF