



Note 1: Cut Termination Bar slightly larger than side of angle iron to allow for compression of Termination Bar by Panduit bands.

Note 2: It is required to use 2 Panduit stainless steel bands.

Note 3: Circumference of round Stack Flashing should be equal to or greater than all sides of angle iron.

Note 4: Round flashings cannot be field-fabricated.

Note 5: All field welds must be a minimum of 1-1/2 inches wide.

Note 6: Refer to specifications for vapor barrier, insulation, and cover board requirements.

REVISED: 06/22/2026	ROOF PENETRATION DETAIL FOR MECHANICALLY FASTENED SYSTEMS
PREVIOUS: 02/02/2017	ANGLE IRON FLASHING
SCALE: NONE	NEW CONSTRUCTION OR RE-ROOF