



Note 1: It is not recommended to exceed 18 inches in height when using deck sheet reverse tabs to flash walls.

Note 2: This detail is not recommended when tapered insulation transitions along the walls.

Note 3: Membrane fastening at deck-to-wall transitions and walls shall be same as per respective zones that area is located within (field, perimeter, corner).

Note 4: Minimum termination height for parapet wall flashing is 8 inches above the finished deck. Refer to Detail Drawing 6020.

Note 5: Refer to specifications for vapor barrier, insulation and cover board requirements.

REVISED: 02/03/2017	PARAPET WALL DETAIL FOR MECHANICALLY FASTENED SYSTEMS
PREVIOUS: 01/01/2009	REVERSE TAB ON WALL
SCALE: NONE	NEW CONSTRUCTION OR RE-ROOF