



Termination Bar and approved
Duro-Last fasteners
spaced 6 inches on center

Duro-Last membranes

Note 2

Approved Duro-Last
sealant

Note 1: Minimum termination height for parapet wall flashing is 8 inches above finished deck. Refer to Detail Drawing 6020.

Note 2: Install approved slip sheet, if required.

Note 3: This detail may not be applicable for vertical metal panel siding. Special consideration shall be taken to ensure structural integrity of the wall is not compromised due to cutting of siding.

REVISED:	11/14/17	PARAPET WALL DETAIL FOR MECHANICALLY FASTENED SYSTEMS
PREVIOUS:	08/01/17	WALL COVERING TERMINATION
SCALE:	NONE	NEW CONSTRUCTION OR RE-ROOF