



Note 1: Membrane fastening at deck-to-wall transitions and walls shall be same as per respective zones that area is located within (field, perimeter, corner).

Note 2: Refer to Detail Drawing 6010 for tab spacing.

Note 3: All field welds shall be a minimum of 1-1/2 inches wide.

Note 4: Refer to specifications for vapor barrier, insulation and cover board requirements

|           |          |   |
|-----------|----------|---|
| REVISED:  | 11/21/17 | LIGHTNING PROTECTION DETAIL FOR MECHANICALLY FASTENED SYSTEMS |
| PREVIOUS: | 07/26/17 | LIGHTNING PROTECTION ON WALL                                  |
| SCALE:    | NONE     | NEW CONSTRUCTION OR RE-ROOF                                   |