



Note 1: Membrane fastening at deck-to-wall transitions and walls shall be same as per respective zones that area is located within (field, perimeter, corner).

Note 2: Refer to Detail Drawing 6010 for tab spacing.

Note 3: All field welds shall be a minimum of 1-1/2 inches wide.

Note 4: Refer to specifications for vapor barrier, insulation and cover board requirements.

REVISED: 02/23/2017	LIGHTNING PROTECTION DETAIL FOR MECHANICALLY FASTENED SYSTEMS
PREVIOUS: 01/01/2009	LIGHTNING PROTECTION ON WALL
SCALE: NONE	NEW CONSTRUCTION OR RE-ROOF