



Note 1: Approved edge details may be used in place of Termination Bar.

Note 2: Wood nailers must withstand a minimum force of 180 pounds per lineal foot (per building code). Any pull values greater than 270 pounds will allow for a fastener spacing of 18 inches on center. Pull values less than 270 pounds will require additional fasteners. The installing contractor is responsible for meeting building codes.

Note 3: Refer to Detail Drawings 8000 and 8005 for insulation, cover board and hard board installation requirements.

| | | |
|-----------|----------|-----------------------------|
| REVISED: | 11/22/17 | METAL ROOF RECOVER |
| PREVIOUS: | 07/26/17 | EDGE TERMINATION |
| SCALE: | NONE | NEW CONSTRUCTION OR RE-ROOF |