



Note 1: Approved edge details may be used in place of Termination Bar.

Note 2: Wood nailers must withstand a minimum force of 180 pounds per lineal foot (per building code). Any pull values greater than 270 pounds will allow for a fastener spacing of 18 inches on center. Pull values less than 270 pounds will require additional fasteners. **The installing contractor is responsible for meeting building codes.**

Note 3: Refer to Detail Drawings 8000 and 8005 for insulation, cover board and hard board installation requirements.

REVISED: 03/16/2017	METAL ROOF RECOVER
PREVIOUS: 01/01/2009	EDGE TERMINATION
SCALE: NONE	NEW CONSTRUCTION OR RE-ROOF