



Note 1: Membrane fastening at deck-to-wall transitions and walls shall be same as per respective zones that area is located within (field, perimeter, corner).

Note 2: All field welds shall be a minimum of 1-1/2 inches wide.

Note 3: Wood nailers must withstand a minimum force of 180 pounds per lineal foot (per building code). Any pull values greater than 270 pounds will allow for a fastener spacing of 18 inches on center. Pull values less than 270 pounds will require additional fasteners. **The installing contractor is responsible for meeting building codes.**

Note 4: Refer to Detail Drawings 8000 and 8005 for insulation, cover board and hard board installation requirements.

REVISED: 04/08/2017

METAL ROOF RECOVER

PREVIOUS: 01/01/2009

RIDGE VENT TERMINATION

SCALE: NONE

NEW CONSTRUCTION OR RE-ROOF