



Note 1: A 1/4-inch gap is required between sections of Duro-Last termination bar.

Note 2: A wood nailer is required if 1-inch of insulation or greater is used. Top of wood nailer to be flush with top of insulation. Fasteners used to attach wood nailers shall be spaced no greater than 18 inches on center.

Note 3: For substrate options refer to Section 2 of the Adhered Duro-fleece Roofing system specification.

Note 4: For approved adhesives refer to Section 2 of the Adhered Duro-Fleece Roofing System specification.

REVISED:	12/14/17	ADHERED DURO-FLEECE MEMBRANE
PREVIOUS:	08/07/17	NON-REMOVABLE GUTTER
SCALE:	NONE	RECOVER OR RE-ROOF