



Note 1: A 1/4-inch gap is required between sections of Duro-Last Termination Bar.

Note 2: Gutter strap spacing per gutter manufacturer's instructions.

Note 3: Duro-Last membrane must be a minimum of 6 inches wide and be same or greater mil thickness as Duro-Fleece membrane.

Note 4: All field welds shall be a minimum of 1-1/2 inches wide.

Note 5: Wood nailers must withstand a minimum force of 180 pounds per lineal foot (per building code). Any pull values greater than 270 pounds will allow for a fastener spacing of 18 inches on center. Pull values less than 270 pounds will require additional fasteners. **The installing contractor is responsible for meeting building codes.**

Note 6: Refer to specifications for vapor barrier, insulation and cover board requirements.

REVISED: 08/31/2017	EDGE DETAIL FOR ADHERED DURO-FLEECE® SYSTEMS
PREVIOUS: 07/08/2017	TERMINATION BAR INTO GUTTER
SCALE: NONE	NEW CONSTRUCTION OR RE-ROOF