



Note 1: An overlap of 1 1/2-inches will be required between sections of vinyl-coated metal. A bead of caulk is required at each overlap.

Note 2: for approved adhesives refer to Section 2 of the Adhered Duro-Fleece Roofing System specification.

Note 3: For adhered installations a cleat must be installed on all vinyl-coated metal driip edge and must be fastened 6-inches on center into an approved structural specification.

Note 4: for substrate options see Section 2 of the Adhered Duro-Fleece Roofing System specification.

Note 5: A wood nailer is required if 1-inch of insulation or greater is used. Top of wood nailer to be flush with top of insulation. Fasteners used to attach wood nailers shall be spaced no greater than 18-inches on center.

REVISED:	12/15/17	ADHERED DURO-FLEECE MEMBRANE
PREVIOUS:	08/07/17	VINYL-COATED METAL DRIP EDGE
SCALE:	NONE	NEW CONSTRUCTION OR RE-ROOF