



Note 1: A 1/4-inch gap is required between sections of duro-Last fascia base. Joints on the fascia base must be offset by a minimum of 12-inches from the joints in the metal cover.

Note 2: A wood nailer is required if 1-inch of insulation or greater is used. Top of wood nailer to be flush with top of insulation. Fasteners used to attach wood nailers shall be spaced no greater than 18-inches on center.

Note 3: The fascia base system is not to be installed as a gravel/water stop.

Note 4: This edging is available in 3-inch through 8-inch dimensions.

Note 5: For substrate options see Section 2 of the Adhered Duro-Fleece Roofing System specification.

Note 6: For approved adhesives refer to Section 2 of the Adhered Duro-Fleece Roofing System Specification.

REVISED:	12/15/17	ADHERED DURO-FLEECE MEMBRANE
PREVIOUS:	07/08/17	3 TO 8-INCH FASCIA BASE
SCALE:	NONE	NEW CONSTRUCTION OR RE-ROOF