



Note 1: Use one of these options for fastening the roof system at the roof-to-wall transition when the wall flashing is adhered. See DF6010 for mechanical attachment wall flashing.

Note 2: Minimum termination height for wall flashing is 8-inches above the finished deck.

Note 3: For substrate options see Section 2 of the Adhered Duro-fleece Roofing System specification.

Note 4: For approved adhesives refer to Section 2 of the Adhered Duro-Fleece Roofing system specification.

Note 5: Field weld Duro-Last membrane. Membrane must be at least 6 inches wide and be the same mil thickness as the Duro-Fleece membrane.

REVISED:	01/10/18	ADHERED DURO-FLEECE MEMBRANE
PREVIOUS:	08/07/17	ADHERED PARAPET WALL FLASHING - OPTION 1
SCALE:	NONE	NEW CONSTRUCTION OR RE-ROOF