



Note 1: This detail may also be used on parapet walls.

Note 2: A 1/4-inch gap is required between sections of Duro-Last Termination Bar.

Note 3: All vertical applications require approved Duro-Last caulk to be applied on both sides of the Termination Bar.

Note 4: Termination Bar is not to be used as a gravel/water stop. Termination Bar and caulk must be located below roof line.

Note 5: Wood nailers must withstand a minimum force of 180 pounds per lineal foot (per building code). Any pull values greater than 270 pounds will allow for a fastener spacing of 18 inches on center. Pull values less than 270 pounds will require additional fasteners. **The installing contractor is responsible for meeting building codes.**

Note 6: Refer to specifications for vapor barrier, insulation and cover board requirements.

REVISED: 02/23/2017	EDGE DETAIL FOR ADHERED SYSTEMS
PREVIOUS: 01/01/2009	TERMINATION BAR
SCALE: NONE	NEW CONSTRUCTION OR RE-ROOF