



Note 1: An overlap of 1 1/2-inches will be required between sections of vinyl-coated metal. A bead of caulk is required in each overlap.

Note 2: A wood nailer is required if 1-inch of insulation or greater is used. Top of wood nailer to be flush with top of insulation. Fasteners used to attach wood nailers shall be spaced no greater than 18-inches on center.

Note 3: For fully adhered installations, a cleat must be installed on all vinyl-coated metal drip edge and must be fastened 6-inches on center.

Note 4: DensDeck® Prime is recommended substrate board. For additional substrate options see Section 2 of the Adhered Specification or contact the Duro-Last Engineering Services Department

Note 5: This detail may also be used on parapet walls.

Note 6: All field welds shall be a minimum of 1-1/2 inches wide.

Note 7: Wood nailers must withstand a minimum force of 180 pounds per linear foot (per building code). Any pull values greater than 270 pounds will allow for a fastener spacing of 18 inches on center. Pull values less than 270 pounds will require additional fasteners. **The installing contractor is responsible for meeting building codes.**

REVISED:	12/15/17	EDGE DETAIL FOR ADHERED SYSTEMS
PREVIOUS:	07/24/17	VINYL-COATED METAL DRIP EDGE
SCALE:	NONE	NEW CONSTRUCTION OR RE-ROOF