



Note 1: 3.2 square feet per fastener.

Note 2: Perimeter width equals the lesser of 10% of narrowest building dimension or 40% of building height.

Note 3: Contact Duro-Last® Engineering Services Department for assistance in determining fastening requirements if: building is 40 feet tall, or taller; or building is located in an area with an ASCE 7-05 design wind speed of 110 mph, or higher (150 mph, or higher, for ASCE 7-10); or fastener pullout resistance is less than 150 lb.

Note 4: It is recommended to stagger all joints between boards by 50% from row to row and layer to layer.

Note 5: Adjoin panel edges together. Neatly fit to roof deck and around penetrations with no gaps greater than 1/4 inch. Seal all penetrations and deck/wall transitions.

REVISED: 05/18/2017	INSULATION DETAIL FOR ADHERED SYSTEMS
PREVIOUS: 01/01/2009	4 X 8-FOOT INSULATION/COVER BOARD - FIELD FASTENING
SCALE: NONE	NEW CONSTRUCTION OR RE-ROOF