



Note 1: Appropriate Duro-Last termination must be followed.

Note 2: Wood blocking must be installed below support if insulation is used.

Note 3: Wood nailers must withstand a minimum force of 180 pounds per lineal foot (per building code). Any pull values greater than 270 pounds will allow for a fastener spacing of 18 inches on center. Pull values less than 270 pounds will require additional fasteners. **The installing contractor is responsible for meeting building codes.**

Note 4: Refer to specifications for vapor barrier, insulation and cover board requirements.

| | |
|----------------------|---|
| REVISED: 07/05/2023 | ROOF PENETRATION DETAIL FOR MECHANICALLY FASTENED SYSTEMS |
| PREVIOUS: 01/27/2017 | LADDER REST |
| SCALE: NONE | NEW CONSTRUCTION OR RE-ROOF |