



Note 1: Appropriate Duro-Last termination must be followed.

Note 2: Wood blocking must be installed below support if insulation is used.

Note 3: Wood nailers must withstand a minimum force of 180 pounds per lineal foot (per building code). Any pull values greater than 270 pounds will allow for a fastener spacing of 18 inches on center. Pull values less than 270 pounds will require additional fasteners.

The installing contractor is responsible for meeting building codes.

Note 4: Refer to specifications for vapor barrier, insulation and cover board requirements.

REVISED:	07/06/23	ROOF PENETRATION DETAIL FOR MECHANICALLY FASTENED SYSTEMS
PREVIOUS:	11/10/17	LADDER REST EXTENSION
SCALE:	NONE	NEW CONSTRUCTION OR RE-ROOF