



Note 1: Overlap each 10 ft (3 m) length of base by 1 in. (25 mm) Overlap the covers by 1-1/2 in. (38 mm) utilizing the pre-notched end on 10 ft (3 m) lengths.

Note 2: Refer to General Requirements for wood nailer requirements.

Note 3: Refer to specifications for vapor barrier, insulation, and cover board requirements

REVISED: 06/16/2026	EDGE DETAIL FOR MECHANICALLY FASTENED SYSTEMS
PREVIOUS: 06/16/2018	ALLTERM®
SCALE: NONE	NEW CONSTRUCTION OR RE-ROOF