



Note 1: Vented Ridge Cap comes in 10-foot lengths with a factory-welded 6-inch skirt on each side. Splice plates are used to join sections.

Note 2: For all construction types, contractor shall follow building codes to determine opening size needed underneath the Vented Ridge Cap.

Note 3: Duro-Last membrane must be installed prior to installation of Vented Ridge Cap.

Note 4: 16-gauge support chair brackets are required at 5-foot on center intervals.

Note 5: Refer to product data sheet for area of venting requirements.

Note 6: All field welds shall be a minimum of 1-1/2 inches wide.

Note 7: Refer to specifications for vapor barrier, insulation and cover board requirements.

REVISED:	12/5/17	VENT DETAIL FOR MECHANICALLY FASTENED SYSTEMS
PREVIOUS:	07/25/17	VENTED RIDGE CAP
SCALE:	NONE	NEW CONSTRUCTION OR RE-ROOF