



Field weld  
(Note 3)

Termination Bar or  
3-Inch Metal Plates  
and  
approved Duro-Last  
fasteners spaced  
6 inches on center

Duro-Last®  
membranes

Approved Duro-Last-  
membrane adhesive

Approved  
cover board (Note 4)

Approved insulation  
(Note 4)

Deck —  
Approved vapor barrier —  
(Note 4)

Note 1: When deck and wall membranes are adhered, refer to Detail Drawings AS6010 and AS6011.

Note 2: Minimum termination height is 8 inches above finished roof deck. Refer to Detail Drawing 6010 for tab spacing requirements.

Note 3: All field welds shall be a minimum of 1-1/2 inches wide.

Note 4: Refer to specifications for vapor barrier, insulation and cover board requirements.

REVISED:	03/28/24	EDGE DETAIL FOR ADHERED SYSTEMS
PREVIOUS:	08/07/17	MECHANICALLY FASTENED WALL FLASHING - OPTION 2
SCALE:	NONE	NEW CONSTRUCTION OR RE-ROOF