



Note 1: Follow adhered (AS) details for adhered parapet terminations.

Note 2: When deck membrane is adhered and parapet membrane is mechanically fastened, refer to details AS6000 and AS6001.

Note 3: Minimum termination height is 8 in. (203 mm) above finished roof deck.

Note 4: Fasten membrane 6 in. (152 mm) on center with approved plates/fasteners.

Note 5: When parapet flashing height exceeds 5 ft (1.5 m), install horizontal rows of plates/fasteners spaced 12 in. (305 mm) on center at 5 ft intervals along rows.

Note 6: Any approved membrane plate may be used. It is recommended to use 3-Inch Metal Plates or Cleat Plates®.

Note 7: All field welds must be a minimum of 1-1/2 in. (40 mm) wide.

Note 8: Refer to specifications for vapor barrier, insulation, and cover board requirements.

REVISED: 05/08/2026	PARAPET DETAIL FOR ROLL GOOD MECHANICALLY FASTENED SYSTEMS
PREVIOUS: 09/25/2017	ADHERED PARAPET FLASHING
SCALE: NONE	NEW CONSTRUCTION OR RE-ROOF