



Note 1: This detail can only be used on parapet walls when termination over the parapet wall edge is not permissible or possible.

Note 2: Skirt must meet the mil thickness necessary for the desired warranty term.

Note 3: All field welds shall be a minimum of 1-1/2 inches wide.

Note 4: Strip Mastic must be within 1/2 inch of outside parapet edge. Ensure that Duro-Edge covers Strip Mastic.

Note 5: Membrane fastening at walls shall be same as per respective zones that area is located within (field, perimeter, corner).

Note 6: A 1/8-inch gap is required between sections of Duro-Edge.

Note 7: Each section of Duro-Edge must have an approved Duro-Last fastener and 3-inch Metal Plate fastened within 1 inch of each end.

REVISED: 08/07/2019	EDGE DETAIL FOR MECHANICALLY FASTENED SYSTEMS
PREVIOUS: 03/29/2019	DURO-EDGE
SCALE: NONE	NEW CONSTRUCTION OR RE-ROOF