



Note 1: Deck membrane shall be fastened around perimeter of roof penetration as per respective zone the rectangular penetration is located within (field, perimeter, corner). As an alternative to deck fastening, plates/fasteners may be fastened to the curb.

Note 2: Termination Bar shall have an approved Duro-Last fastener within 1 inch of each corner.

Note 3: All field welds shall be a minimum of 1-1/2 inches wide.

Note 4: Refer to specifications for vapor barrier, insulation and cover board requirements.

Note 5: Any approved membrane plate may be used. It is recommended to use 3-Inch Metal Plates or Cleat Plates®.

REVISED:	N/A	ROOF PENETRATION DETAIL FOR ADHERED SYSTEMS
PREVIOUS:	03/09/2020	RECTANGULAR PENETRATION
SCALE:	NONE	NEW CONSTRUCTION OR RE-ROOF